

# **INFORMATION SHEET**

## **MOBILE FLEET FUELING OPERATIONS**

A permit shall be obtained for each mobile service vehicle. The service vehicle operating company shall make application to the Las Vegas Fire & Rescue on permit application supplied by the Fire Prevention Division. *NFPA 1: Annex L, Section 3[CLV #5667]*

A permit shall be obtained for each site where mobile servicing occurs. Responsible party for the site shall make application to the Las Vegas Fire & Rescue on permit application supplied by the Fire Prevention Division. *NFPA 1: Annex L, Section 3[CLV #5667]*

- Service vehicles and sites shall be approved prior to any operations being conducted. *NFPA 1: Annex L, Section 3[CLV #5667]*
- The driver, operator or attendant of a tank vehicle shall not leave the vehicle while it is being filled or discharged. Delivery hose, when attached to a tank vehicle, shall be considered to be a part of the tank vehicle. *NFPA 385: 6-2.2*
- Before dispensing Class I, II or III liquid fuels when heated above their flashpoint, into the tanks of motor vehicles, the vehicles shall be electrically bonded. *NFPA 1: Annex L, Section 7.9 [CLV #5667]*
- The Fire Department shall be notified immediately when a spill or unauthorized discharge occurs greater than 5 gallons; creates a hazard to life and/or property; or required by federal, state or local regulations. *NFPA 1: Annex L, Section 7.2[CLV #5667]*
- Smoking by tank vehicle drivers, helpers, repairmen or other personnel is prohibited while they are making deliveries, filling or making repairs to tank vehicles. *NFPA 1: Annex L, Section 7.3[CLV #5667]*
- Dome covers shall be closed and latched while the tank vehicle is in transit. *NFPA 385: 6-1.2*
- All service vehicles transporting Class I, II or III flammable/combustible liquids shall carry markings to meet the requirements of *49 CFR* and the requirements of the *U.S. Department of Transportation Hazardous Materials Regulations*. *NFPA 1: Annex L, Section 6.1(7) [CLV #5667]*
- Vehicles shall not be operated unless they are in proper repair and free of accumulation of grease, oil or other flammables, and leaks. *NFPA 1: Annex L, Section 6.1(5) [CLV #5667]*

*continued on back...*

- Vehicles and sites shall comply with the following: *NFPA 1: Annex L [CLV #5667]*
  - Dispensing may only occur at sites (commercial or industrial zoned) that have been permitted to conduct mobile fueling.
  - The service vehicle's specific function must be that of supplying fuel to motor vehicle fuel tanks.
  - The service vehicle's dispensing line does not exceed 100 feet in length.
  - The dispensing nozzle is of an approved type.
  - The dispensing nozzle will not pump unless it is in proper contact with the fuel opening of the motor vehicle to be filled.
  - The dispensing hose is properly placed on the approved reel or in an approved compartment prior to moving the vehicle.
  - Signs prohibiting smoking or ignition sources within 25 feet of a tank vehicle or the point of fueling are prominently posted.
  - Tank vehicle dispensing equipment is operated only by designated personnel who are trained to handle and dispense motor fuels.
  - Persons responsible for dispensing operations shall be trained in the appropriate mitigating actions necessary in the event of a fire, leak or spill.
  - Training records shall be maintained by the company and shall be made available to the authority having jurisdiction upon request.
  - Absorbent materials and an approved container shall be provided to mitigate a minimum 5-gallon fuel spill.
  - A fire extinguisher with a minimum of 4A-40B:C shall be provided on all vehicles with signage clearly indicating its location.
  - All fueling equipment shall be stored within the body of mobile-fueled vehicle.
  - Fueling shall not take place within 15 feet of property lines, streets, alleys, public ways, building openings and storm drains.
  - Fueling shall not take place within 50 feet of property lines or important buildings when dispensing Class I liquids.

*The items listed are basic information only. Codes are subject to change. Additional requirements may apply.*

**LAS VEGAS FIRE & RESCUE**  
**Fire Prevention Division**  
**(702) 229-0366**  
**[www.lasvegasfire.org](http://www.lasvegasfire.org)**